

1008 W. Ahtanum Rd.  
 Union Gap, WA 98903  
 (509) 452-7707  
 Fax: (509) 452-7773



3019 G.S. Center Rd.  
 Wenatchee, WA 98801  
 (509) 662-1888  
 Fax: (509) 662-8183

Billing Code: 02605  
 Batch #: 757998

## LCR TEST PANEL Lead and Copper Distribution System • Report of Analyses

	System Group Type: (Circle one) <u>A</u> B Other: (Specify)
Water System ID Number <u>12850F</u>	System Name: <u>Chivava Comm Assoc</u>
Source: S93 (Distribution Samples)	County: <u>Chelan</u>
	Consecutive System? <u>      </u> YES <u>      </u> NO
Send Report to: <u>Chivava Communities</u> <u>2651 Cottonwood Lane</u> <u>Leavenworth, WA 98826</u>	Bill to: (Client Name) <u>Chivava Communities</u> <u>2651 Cottonwood Lane</u> <u>Leavenworth, WA 98826</u>
Sample Purpose: (Check Appropriate Box) <input checked="" type="checkbox"/> RC - Routine/Compliance (satisfies monitoring requirements) <input type="checkbox"/> C - Confirmation (confirmation of chemical result) <input type="checkbox"/> I - Investigative (does not satisfy monitoring requirements) <input type="checkbox"/> O - Other (specify)	Date Received: (MM/DD/YY) <u>6</u> / <u>21</u> / <u>17</u> Date Analyzed: (MM/DD/YY) <u>6</u> / <u>22</u> / <u>17</u> Date Reported: (MM/DD/YY) <u>6</u> / <u>22</u> / <u>17</u> COMMENTS:

(DOH #) Analyte	(0023) Copper	(0009) Lead
State Reporting Level (SRL)	0.02 mg/l	0.001 mg/l
Regulatory Action Level	1.3 mg/l	0.015 mg/l
Analytical Method/Analyst's Initials	EPA 200.8 / RLK	EPA 200.8 / RLK

Lab Sample Number	Date Collected	Sample Location	Copper (mg/L)	Lead (mg/L)
10516509	6/21/17	2479 Salal DR	0.0180	0.000600
10516510	6/21/17	2651 Cottonwood Ln	0.0177	0.001050
10516511	6/21/17	2393 Minnick DR	0.765	0.001800
10516512	6/21/17	2219 Riffle DR	0.0500	0.002440
10516513	6/21/17	2602	0.0936	0.001080

**NOTES:**  
**SRL (State Reporting Level):** Indicates the minimum reporting level required by the Washington State Department of Health (DOH)  
**Action Level:** The concentration of the 90th percentile sample of all six-month period distribution samples collected that, if exceeded, signals the system is in violation.  
**NA: Not Analyzed:** In the results column, indicates this compound was not included in the current analysis.  
**ND (Not Detected):** In the results column, indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.  
**<(0.00X):** Indicates the compound was not detected in the sample at or above the concentration indicated. (for labs using their own reporting level)

Comments: *[Signature]*